


TYPICAL CROSS SECTIONS B-11

DISCLAIMER NOTICE:
SPECIFIC INFORMATION
REQUIRED FOR COMPLIANCE
WITH LOCAL CODES IS THE
RESPONSIBILITY OF THE
DESIGNER



DTL-C9 SIMILAR w/4"(100mm) CORE FORM
PRE-ENGINEERED ROOF TRUSSES
OR RAFTERS AS PER CODE

2 LAYERS OF NUDURA CEILING
TECHNOLOGY (OPTIONAL) OR
CONVENTIONAL INSULATION AS
PER CODE

BRICK VENEER 1"(25mm) AIR
SPACE w/BRICK TIES AS PER
CODE

NUDURA 4"(100mm) FORM
HORIZ/VERT REINFORCING AS
PER CODE OR AS SPEC'D IN
APPENDIX 'D' FOR ABOVE GRADE

MIN. 6"(150mm) BELOW GRADE OF
ACRYLIC PARGE COAT

GRADE MIN. 2% SLOPE

NUDURA
WATERPROOFING
MEMBRANE

EXISTING SOIL

BACKFILL SOIL
AS PER CODE

NUDURA 8"(200mm) FORM
HORIZ/VERT REINFORCING AS
PER CODE OR AS SPEC'D IN
APPENDIX 'D' FOR BELOW GRADE

CONTINUOUS 4" (100mm)
ROUND PERFORATED DRAIN TILE
COVERED WITH 6"(150mm)
CRUSHED GRANULAR AS PER
CODE

CONTINUOUS CONCRETE FOOTING ON
UNDISTURBED SOIL AS PER CODE.
FOOTING SIZE AS PER CODE FOR
8"(200mm) CONC. BASEMENT WALL
PLUS ONE STORY CONC. OR MASONRY
WALL (BRICK VENEER FINISH &
PREVAILING SITE CONDITIONS)

*NOTE: IN ADDITION TO FOOTING SIZE INDICATED BY CODE, ADD 1" (25.4mm) WIDTH TO STRIP FOOTING FOR EVERY 1'0" (305mm) OF CONC. WALL HEIGHT ABOVE 8'0" (2440mm)



BUILDING SECTION
BASEMENT 8" (200mm) FORM
1 STOREY 4" (100mm) FORM
BRICK VENEER FINISH

REV. NO.
003 KS

DWG NO.

B-11

REV. DATE:
SEPT 2008

DRAWN BY
J.N / N.L

SCALE:
1/4"=1'-0"