

DISCLAIMER NOTICE:
 SPECIFIC INFORMATION
 REQUIRED FOR COMPLIANCE
 WITH LOCAL CODES IS THE
 RESPONSIBILITY OF THE
 DESIGNER

ANCHOR BOLTS AS REQUIRED
 PER LOCAL CODE

THROUGH WALL FLASHING TO
 EXTEND OVER TAPER TOP FORM
 AND PARGE COAT AS PER CODE

FINISHED GRADE
 MIN. 6" (150mm)
 OR AS PER CODE

LAP VAPOR BARRIER FROM
 FRAME TO INTERIOR FACE
 OF NUDURA FORM

THERMAL BARRIER
 PROTECTION AS REQUIRED
 PER LOCAL CODE

$\frac{3}{16}$ " (5mm) ACRYLIC PARGE
 COAT TO MINIMUM OF 6"
 (150mm) BELOW GRADE

#4 (10M) VERTICAL BAR
 @ 16" (405mm) o.c.

NUDURA DAMPROOFING/
 WATERPROOFING MEMBRANE

#4 (10M) HORIZONTAL
 BAR @ 18" (457mm)

NUDURA 6" (152mm) OR
 8" (203mm) STANDARD
 FORM UNIT

3- #4 (10M) BAR
 CONTINUOUS

DRAINED EARTH IN
 ACCORDANCE w/OBC

3" (75mm) MINIMUM
 CONCRETE COVER TO
 REINFORCEMENT STEEL

*REFER TO STRUCTURAL NOTES
 (C-13)

NUDURA 6" (152mm) OR
 8" (203mm) TAPER TOP
 FORM UNIT

1 $\frac{1}{2}$ " (38mm) CONCRETE
 COVER TO VERTICAL STEEL


NUDURA 6" (152mm) OR
 8" (203mm) STANDARD
 FORM UNIT

#4 (10M) @ 16" (405mm)
 HORIZ x 20" (508mm)
 VERT BENT BARS @ 16"
 (405mm) o.c.

4" (102mm) CONCRETE
 FLOOR SLAB w/ NUDURA
 FLOOR TECHNOLOGY
 (OPTIONAL)



4' - 6" [1372mm] MAX.

8" [203mm]



The architecture, engineering, and design of the project using the Nudura products are the responsibility of the project's design professional. All products and systems must comply with local building codes and standards. This detail is for general information and guidance only and Nudura specifically disclaims any liability for the use of this detail. The project design professional determines, in its sole discretion, whether this detail or a functionally equivalent detail is best suited for the project. This detail is subject to change without notice. Contact Nudura to ensure you have the most recent version.

Typical Details

 Nudura Technical Support: 866-468-6299 International: +1 705-726-9499	Detail: Knee Wall Detail Basement Nudura Form Unit 1 or 2 Story Wood Frame Taper Top Form Unit Brick Veneer Finish		File Name: C-15	 Construction Products Group
	Drawn by: K. Still	Scale: NTS	Date: 10/29/2021	