

GABLE END TRUSS
 INSTALLED TO ALLOW
 SHEATHING TO BE
 INSTALLED FLUSH TO
 FACE OF NUDURA
 FORM UNITS

CROSS BRIDGING AT
 FIRST TRUSSES AS
 MANUFACTURERS
 INSTALLATION
 REQUIREMENTS

BRICK VENEER c/w 1"
 (25mm) AIR SPACE
 AND BRICK TIES

MOISTURE BARRIER
 APPLIED OVER GABLE
 END SHEATHING AND
 LAP NUDURA FORMS
 AT EXTERIOR

2x4" (38x89mm) CROSS
 BLOCKING BETWEEN GABLE
 END AND FIRST TRUSS AT
 24" (600mm) o.c. OR AS
 PER CODE. BLOCKING TOE
 NAILED OR BRACKET
 ANCHORED TO SILL PLATE
 AS SPECIFIED

2x6" (38x140mm)
 SILL PLATE ANCHORED WITH
 1/2" GALVANIZED ANCHOR
 BOLTS AS PER CODE

HORIZ/VERT
 REINFORCEMENT AS PER
 CODE OR AS SPECIFIED

ATTIC INSULATION AS
 PER CODE (AS
 SHOWN) or NUDURA
 CEILING TECHNOLOGY

1/2" (13mm) GYPSUM
 BOARD WITH VAPOR
 BARRIER AS PER
 CODE

2x4"
 (38x89mm) BOTTOM
 CHORD OF GABLE END
 TRUSS END NAILED INTO
 CROSS BLOCKING

NUDURA 8" (203mm)
 STANDARD FORM UNIT

DISCLAIMER NOTICE:
 SPECIFIC INFORMATION
 REQUIRED FOR COMPLIANCE
 WITH LOCAL CODES IS THE
 RESPONSIBILITY OF THE
 DESIGNER



NUDURA

INTEGRATED BUILDING TECHNOLOGY

Building Value.

NUDURA 8" (203mm) FORM UNIT
 GABLE END DETAIL
 TRUSSES PARALLEL TO WALL

REV. NO.
003 KS
 REV. DATE:
SEPT 2010
 DRAWN BY:
T. VAN CLIEAF

DWG NO.
F8B02
 SCALE:
1 : 8