

FLASHING AS SPECIFIED

WOOD BLOCKING AND PLYWOOD AT 5° SLOPE

NON-COMBUSTIBLE FIBERGLASS BATT INSULATION ON VAPOR BARRIER

EXTERIOR FINISH AS SPECIFIED

EPS CANT STRIP

FORM PANELS c/w INSERT WEBS- CUT TO SUIT ROOF CONNECTION- ADDITIONAL FORM SUPPORT AS REQUIRED

FIBER BOARD SUBSTRATE w/ ROOF MEMBRANE ON 3 1/2" (89mm) RIGID INSULATION

ALLOW ROOF SLAB TO REST ON TO BEARING WALL CONCRETE

WET SET DOWELS TO MATCH VERTICAL REINFORCEMENT BETWEEN POUR OR AS SPECIFIED

PROPRIETARY STEEL JOIST FLOOR SYSTEM

NUDURA 10" (254mm) STANDARD FORM UNIT

HORIZ/VERT REINFORCEMENT AS PER CODE OR AS SPECIFIED

CEILING FINISH AS PER STEEL JOIST MANUFACTURERS SPECIFICATION (NOTE: WHERE GYPSUM BOARD IS REQUIRED TO COMPLETE FIRE RATED ASSEMBLY, EPS FOAM KERF CUT TO ENABLE CEILING FINISH TO PROVIDE THERMAL BARRIER CONTACT TO CONCRETE)

1/2" (13mm) GYPSUM BOARD

DISCLAIMER NOTICE: SPECIFIC INFORMATION REQUIRED FOR COMPLIANCE WITH LOCAL CODES IS THE RESPONSIBILITY OF THE DESIGNER



NUDURA

INTEGRATED BUILDING TECHNOLOGY

Building Value.

NUDURA 10" (254mm) FORM UNIT
STEEL JOIST ROOF SYSTEM
EXTERIOR SIDE WALL
EXTERIOR FINISH AS SPECIFIED

REV. NO.
003 KS
DATE:
APRIL 2010
DRAWN BY:
T. VAN CLIEAF

DWG NO.
F10F04
SCALE:
1 : 8